

HURST – EULESS-BEDFORD INDEPENDENT SCHOOL DISTRICT

**NEW PRACTICE FIELD AT TRINITY HIGH SCHOOL
Eules, Texas**

ADDENDUM NO. 03

[One (1) page – 8 ½ x 11 Sheet]

PROJECT: New Practice Field at Trinity High School
Plans and Specifications dated January 22, 2010
HKS Project No. 12899.000

DATE: February 10, 2010

TO: All Offerors

FROM: HKS Inc.
1919 McKinney Avenue
Dallas, Texas 75201
Phone: 214/969-5599



The Proposal Documents shall be amended and/or revised by Addendum hereinafter specified and all Work affected by this Addendum shall be included.

Except as may otherwise be described, labor and material for the Work hereinafter indicated shall conform to all requirements of the original Proposal Documents.

CLARIFICATIONS TO THE SPECIFICATIONS

ITEM NO. 01 SECTION 02311 FINISHED LANDSCAPE GRADING, Section 3.5.A shall be revised as follows:

- A. Strip topsoil from limits of grading areas, clean of grass, roots, rocks and debris to a depth of 8 to 10 inches and stockpile for placement as topsoil. Contractor and school shall investigate the site to determine if suitable material is available on site to meet specifications for topsoil., and remove from site.

CLARIFICATIONS TO THE DRAWINGS

CIVIL DRAWINGS

ITEM NO. 02 SHEET 'L1.00' – LANDSCAPE PLAN

- 1. CLARIFICATION. The note within the TIFWAY 419 Solid sod hatching (North and near centerline of field) which reads "HYDROMULCH TURFGRASS – COMMON BERMUDA GRASS" shall be deleted. This area shall be TIFWAY 419 SOLID SOD TURFGRASS, as the hatch pattern indicates

END OF ADDENDUM