

HURST EULESS BEDFORD INDEPENDENT SCHOOL DISTRICT

CANOPY ADDITION for  
BEDFORD HEIGHTS ELEMENTARY SCHOOL  
Bedford, Texas

ADDENDUM NO. 03

**PROJECT:** HEBISD-Canopy Addition for Bedford Heights Elementary School, Bedford, Texas  
Drawings and Project Manual dated: September 3, 2010  
HKS Project No. 13536.000

**DATE:** September 22, 2010

**TO:** All Offerors

**FROM:** HKS Inc.  
1919 McKinney Avenue  
Dallas, Texas 75201  
Phone: 214/969-5599



The Proposal Documents shall be amended and/or revised by Addendum hereinafter specified and all Work affected by this Addendum shall be included.

Except as may otherwise be described, labor and material for the Work hereinafter indicated shall conform to all requirements of the original Proposal Documents.

**CLARIFICATIONS TO THE PROJECT MANUAL**

- ITEM NO. 01. **SECTION 09 9713 – COATINGS FOR STEEL**, Kelly Moore Paints shall be added as an Acceptable Manufacturer, as follows:
- a. 2.1.A – ACCEPTABLE MANUFACTURERS, Add “Kelly Moore Paints”
  - b. 2.2.B – Intermediate Coat, Add the following:  
“Kelly Moore: “Rustoleum” 9100 System, DTM, Epoxy mastic
  - a. 2.2.C – TopCoat, Add the following:  
“Kelly Moore: “Rustoleum” 9800 System, DTM, urethane mastic

**CLARIFICATIONS TO THE DRAWINGS**

**STRUCTURAL DRAWINGS**

- ITEM NO. 02. **S1.01 – 13. 3-1/2” METAL ROOF DECK**, Note ‘B.2’ shall be added to read as follows:

“2. Metal deck shall be galvanized, factory primed and field painted, color to be selected by Owner and Architect.”

## **ATTACHMENTS**

None.

## **RESPONSES TO BIDDER QUESTIONS**

ITEM NO. 03. Question: “Please clarify metal deck finish.”

a. Response: *“Refer to note added to Structural drawings, this addendum.”*

**END OF ADDENDUM**